



	RESIDENTIAL	COMMERCIAL	INDUSTRIAL
MIN. WIDTH (W)	10	15	20
MAX. WIDTH (W)	30	40	40
MIN. RADIUS (R)	10	15	25
MAX. RADIUS (R)	25	50	50
MIN. ANGLE OF INTERSECTION (A)	45	45	45

TYPE OF DRIVEWAY	MINIMUM SURFACING REQUIREMENTS	MINIMUM BASE ROCK REQUIREMENTS
CONCRETE	6" OF 3000 PSI PORTLAND CEMENT CONCRETE	2" OF SAND OR 2" OF ¾" CRUSHED ROCK
ASPHALT	3" OF ASPHALTIC CONCRETE PAVEMENT	6" OF 1" CRUSHED AGG BASE ROCK

NOT TO SCALE



ENGINEERING & PUBLIC WORKS

## STANDARD DRIVEWAY

APPROVED BY: *Andrew B. Stone*  
 Andrew B. Stone, PE, City Engineer & Director of Public Works

STD. DRAWING #:

# 103

DRAWN BY: Alex Ray, EI

DATE: 8/16/12