

CUSTOMER PIPING SYSTEM

DIRECTION OF FLOW
↑

#7 DUAL CHECK VALVE
WATTS 7U2-2

3/4" x 1/2" REDUCER
BUSHING

1/2" x 5/8" METER NIPPLE

5/8" x 1/2" SENSUS METER
1000 GALLON READ
ECR REGISTER SHOWN
(TYPICAL)

CONTACT ENGINEERING
& PUBLIC WORKS
(740-593-7636)

1/2" x 5/8" METER NIPPLE

3/4" x 1/2" REDUCER

3/4" LOCK WING
BALL VALVE

CITY WATER SUPPLY

NOT TO SCALE



ENGINEERING &
PUBLIC WORKS

STANDARD WATER METER

APPROVED BY: *Andrew B. Stone*
Andrew B. Stone, PE, City Engineer & Director of Public Works

STD. DRAWING #:

301

DRAWN BY: Alex Ray, EI

DATE: 8/16/12