



GATE VALVE NOTES:

1. STEM EXTENSIONS: PROVIDE TO BRING OPERATING NUT TO BETWEEN 30 AND 48 INCHES OF FINISHED GRADE IF VALVE-OPERATING NUT IS GREATER THAN 48 INCHES DEEP
2. USE FOR WATERLINE UP TO 14 INCHES DIAMETER
3. CONFORMANCE AWWA C509 FOR RESILIENT SEATED VALVES.
4. PRESSURE CLASS 250.
5. JOINTS: MECHANICAL JOINT WITH GRIP RING RESISTANT.
6. OPERATION: NON-RISING STEM, 2" SQUARE OPERATING NUT AND OPEN COUNTER CLOCKWISE.
7. APPROVED MANUFACTURERS:
 - A. AMERICAN FLOW CONTROL
 - B. WATEROUS
 - C. CLOW

NOT TO SCALE



ENGINEERING &
PUBLIC WORKS

**M.J. VALVE &
VALVE BOX DETAIL**

APPROVED BY: *Andrew B. Stone*
Andrew B. Stone, PE, City Engineer & Director of Public Works

STD. DRAWING #:

307

DRAWN BY: Alex Ray, EI

DATE: 8/16/12