



NOTE:
 WHEN INSTALLING A DOUBLE CLEANOUT, IT IS RECOMMENDED THAT THEY BE
 INSTALLED IN THE MANNER SHOWN ABOVE. IF INSTALLED "BACK-TO-BACK", THERE
 WILL BE A DEAD SPOT IN THE LINE THAT CANNOT BE ACCESSED WITH SEWER
 CLEANING EQUIPMENT.

4" 6" OR 8" SDR35,
 AS REQUIRED BY
 SYSTEM SIZING.

NOT TO SCALE



ENGINEERING &
 PUBLIC WORKS

DOUBLE CLEANOUT INSTALLATION

APPROVED BY: *Andrew B. Stone*
 Andrew B. Stone, PE, City Engineer & Director of Public Works

STD. DRAWING #:

505

DRAWN BY: Alex Ray, EI

DATE: 8/16/12